

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/Agr/26/05/139

Dated: 20/05/2026

It is certified that an inspection team headed by Er. Vipin Agarwal / Amita Devi

(Name of Officers with designation) from U.P. Jal Nigam (Rural) Agra PHED

inspected the Jyoti Punj Public School Kakrara (Firozabad)

(Name & Address of the school) on 16/05/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPJN/Agr/26/05/139 dated 20/05/2026

of Regional Water Testing Laboratory Agra (PHED Lab) certified that

the Jyoti Punj Public School Kakrara (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year from issue date

Your text here 1

Signature with Seal: सहायक अभियन्ता

Name: विपिन आगरवाल

Designation: अ.ए.

Name & Address of the Office / Department: U.P. Jal Nigam Agra

To Principal
Jyoti Punj Public School Firozabad
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Lab Incharge
Amita Devi

JAISHREE
E YADAV
Digitally signed by JAISHREE YADAV
Date: 2026.09.08 20:26:31 +05'30'

PRIYANK
A YADAV
Digitally signed by PRIYANKA YADAV
Date: 2026.09.08 20:26:51 +05'30'

Jaishree
Principal
Jyoti Punj Public School
Kakrara (Firozabad)

Priyanka Yadav
MANAGER
JYOTI PUNJ PUBLIC SCHOOL
KAKRARA (FIROZABAD)



Regional Water Testing Laboratory

Address: 4/4 Sanjay Place U.P. Jal Nigam (Rural) Agra, 282002



TEST REPORT

Report No:	UPJN/AGR/26/05/139	Issue Date:	20/05/2026	Page No	1
Remark :	-				
Customer Details					
Office Name and Address	JYOTI PUNJ PUBLIC SCHOOL KAKRARA (FIROZABAD)				
Ref Letter No & Date	N/A /2026-27 & 16-05-2026				
Basic details of sample					
District	Firozabad	Block/City	Firozabad		
Gram Panchayat		Village/city	Kakrara		
Water Source	R.O.	Location	JYOTI PUNJ PUBLIC SCHOOL KAKRARA FIROZABAD		
Quantity of Sample	1 Lt.	Sample No.	01		
Receiving Date	16/05/2026	Date of Collection	16/05/2026		
Sample Depositor	Mrs. Priyanka Yadav	S. Collector	Mrs. Priyanka Yadav		
Analysis Start Date	17/05/2026	Sampling Method	As per IS 17614: Part 1: 2021		
		Analysis Completion Date:	18/05/2026		

Technical Data of Analysis

S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130)
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.32	6-8.5	6.5-8.5	IS 3025 (Part 11):2022(Electrometric method)
2	Turbidity NTU	0.923	1	5	IS 3025 (Part 10):2023 (Nephelometric Method)
3	Total Dissolved Solid mg/L	155	500	2000	IS 3025 (Pt 16):2023 (Gravimetric Method)
4	Fluoride mg/L	-	1	1.5	APHA 24 th Edition 4500-F Method C (Electrode method) 2023
5	Total Hardness mg/L	36	200	600	IS 3025 (Part 21):2023(EDTA Method)
6	Total Alkalinity mg/L	60	200	600	IS 3025 (Part 23) 1986 (Potentiometric method)
7	Chloride mg/L	42	250	1000	IS 3025 (Part 32):2025 (Argentometric method)
8	Iron mg/L	--	1	1	APHA 24 th Edition 3500-Fe Method B (Phenanthroline Method) 2023
9	Sulphate mg/L	NIL	200	400	APHA 24 th Edition 4500-SO4 Method E (Turbidity Method) 2023
10	Calcium mg/L	18	175	200	IS 3025 (Part 40) 2024(EDTA Titrimetric Method)
11	Magnesium mg/L	7.77	30	100	IS 3025 (Part 46) 2023(Volumetric Method)
12	Color (Hazen)	1	5	15	IS3025 Edition(Part 4) Color (Visual Comparison Method)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 2023 (Qualitative Method)
14	Nitrate (mg/l)	NIL	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)

Note:


1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests


Prepared by


 (Amrita Devi)
 Authorized Signatory:
 Testing Lab In charge

Laboratory Contact details
Mob. (8630905287)

End of Report


Principal
 Jyoti Punj Public School
 Kakrara (Firozabad)


MANAGER
 JYOTI PUNJ PUBLIC SCHOOL
 KAKRARA (FIROZABAD)



Analysis Report
Regional Water Testing Laboratory
Address :4/4 Sanjay Palace U.P. Jal Nigam(Rural), Agra, 282002

Report No.	Agr/micro/140/2026-27	Issue Date:	20/05/2026		
Remark				Page No	1
Contact Person:	Amita Devi	Address:	UPJN Agra	Mob:	8630905287

Customer Details

Office Name and Address	JYOTI PUNJ PUBLIC SCHOOL KAKRARA (FIROZABAD)
Ref Letter No & Date	N/A /2026-27 & 16-05-2026

Basic details of sample

District	Firozabad	Block/city	Firozabad
Gram Panchayat	-	Village/Mohalla	Kakrara
Habitation	-	Location	JYOTI PUNJ PUBLIC SCHOOL KAKRARA FIROZABAD
Water Source	R.O. Water	Sample No.	01
Quantity of Sample	1 L	Date of Collection	16/05/2026
Receiving Date	16/05/2026	S. Collector	Mrs. Priyanka Yadav
Sample Depositor	Mrs. Priyanka Yadav	Sampling Method	IS 1622 : 1981
Analysis Start Date	17/05/2026	Analysis Completion Date:	18/05/2026

Technical Data of Analysis

S.No	Analyzed parameters	Unit of Measurement	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2		3	4	5	6
1	pH	-	7.32	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Total Coliform	CFU/100 ml	00	No Relaxation	No Relaxation	IS 15185:2016
3	E.Coli	CFU/100 ml	00	No Relaxation	No Relaxation	IS 15185 : 2016

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.



Aditya Kumar Singh
(Microbiologist)


Amita Devi
(Lab In-Charge)

Laboratory Contact details

Email- regionalwatertestinglabagra@gmail.com


Principal
Jyoti Punj Public School
Kakrara (Firozabad)


MANAGER
JYOTI PUNJ PUBLIC SCHOOL
KAKRARA (FIROZABAD)